

Certificate

Registration No.: PV 60036628

Page 1

Report No.: 21208360-1

License Holder:

GD Solar (Jiangsu) Co., Ltd.

Dongjiu Avenue
Yixing Economic Development Zone
Jiangsu 214213
China

Product:

PV Module

Type:

GDM-80ME02, GDM-85ME02, GDM-90ME02,
GDM-160ME01, GDM-165ME01, GDM-170ME01,
GDM-175ME01, GDM-180ME01, GDM-185ME01.

Manufacturing Plant:

0001--21139433 001

Basis:

- IEC 61215:2005**
EN 61215:2005
"Crystalline silicon terrestrial
photovoltaic (PV) modules - Design
qualification and type approval"

- Factory Inspection**
To document the consistent quality of
the product factory inspections are
performed periodically.



- Qualified, IEC 61215
- Periodic Inspection

Remarks:

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 15 December 2013.

Cologne, 21 December 2010



Dipl.-Ing. M. Adrian

Certificate

Registration No.: PV 60036629

Page 1

Report No.: 21208360-2

License Holder:

GD Solar (Jiangsu) Co., Ltd.

Dongjiu Avenue
Yixing Economic Development Zone
Jiangsu 214213
China

Product:

PV Module

Type:

GDM-80ME02, GDM-85ME02, GDM-90ME02,
GDM-160ME01, GDM-165ME01, GDM-170ME01,
GDM-175ME01, GDM-180ME01, GDM-185ME01.

Manufacturing Plant:

0001--21141174 001

Basis:

- IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

- Factory Inspection**
To document the consistent quality of the product factory inspections are performed periodically.



- Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic Inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 15 December 2013.

Cologne, 21 December 2010



Dipl.-Ing. M. Adrian